



VICTOR KHANYE LOCAL MUNICIPALITY

PUBLIC NOTICE

PUBLICATION OF DRINKING WATER QUALITY COMPLIANCE

January to December 2016

DRINKING WATER PARAMETER	REQUIRED COMPLIANCE TO SANS 241:2015 STANDARD (%)	ACHIEVED COMPLIANCE TO SANS 241:2015 (%)	COMPLIANCE STATUS
Microbiological	≥ 95 - ≥ 97	100%	Complying
Chemical	≥ 95 - ≥ 97	100%	Complying
Physical	≥ 93	100%	Complying
Operational	≥ 90	98%	Complying

January to December 2017

DRINKING WATER PARAMETER	REQUIRED COMPLIANCE TO SANS 241:2015 (%)	ACHIEVED COMPLIANCE TO SANS 241:2015 (%)	COMPLIANCE STATUS
Microbiological	≥ 95 - ≥ 97	98%	Complying
Chemical	≥ 95 - ≥ 97	96%	Complying
Physical	≥ 93	100%	Complying
Operational	≥ 90	100%	Complying